



Guidelines cont'd.

- C. should be simple rather than ornate in design. It is recommended that wood decks have square wood balusters set no more than three inches apart. Balusters should be no more than 2" in width and depth.
- D. railings should continue the line and spacing of existing balustrades.
- E. second story decks and balconies should not be built on primary elevations, but may be appropriate on rear elevations.

4. Room and wing additions

DESIGN PRINCIPLE: In planning additions, the best approach is to place the additions where they will have the least impact on the building's overall form and plan. The rear of buildings is the best location for the addition of rooms or wings. Exterior walls of new additions should not be flush with those of existing buildings, but should be stepped in a minimum of 12" from the edges of the existing building. Likewise, addition rooflines should be stepped down from the peak of the existing roofline so that the existing main roof remains evident. Enlarging a property through adding stories is not appropriate.

Additions:

- A. are most appropriately located at the rear of buildings.
- B. should be secondary (smaller and simpler) to the original building in scale, design, and placement. The use of a small connector or link between the addition and the original building is encouraged where appropriate. Exterior walls should be stepped in a minimum of 12" from the edges of the existing building, and rooflines should be stepped down from the peak of the existing roofline so that the existing main roof remains evident.
- C. should be a compatible design in keeping with the original building's design, roof shape, materials, color and location of window, door and cornice heights.
- D. should not imitate an earlier historic style or architectural period. For example, a Greek Revival style rear porch addition would not be appropriate for a Queen Anne style house.
- E. should reflect characteristics of the current period in design, but be compatible with the original building.
- F. should be built in a manner that avoids substantive removal or loss of historic materials and which does not damage or destroy the main architectural features of the building.
- G. should keep the exterior walls of the original building as intact as possible and use existing door and window openings for connecting the addition to the building.
- H. should not be made by adding new stories.
- I. should be of materials compatible with the historic fabric of the house. The use of wood is most appropriate; however cementitious board may be considered for additions.
- J. should have skylights, decks, or balconies placed so that they do not detract from the historic character of the building.

Guidelines cont'd.

III. Guidelines for site and setting

In addition to buildings, elements of the surrounding site and setting contribute to the character of historic properties. These elements include both natural and manmade features such as trees, fields, gardens, fences, driveways, retaining walls and boundary definers. Historic site elements help to define a property's historic character and appearance. Historic site and setting features should be preserved and maintained.

4. Sidewalks, Walkways and Curbs

DESIGN PRINCIPLE: Sidewalks, walkways and curbs in Lexington's historic districts are constructed primarily of concrete with some brick walkways and some limestone curbs. These elements help to define the character of the districts and should be preserved and maintained.

- A. that are significant paved surfaces should be maintained and preserved.
- B. that are added or altered should be compatible with the principal and accessory structures on the property and surrounding historic properties.
- C. that are added should not be visually dominant, intrusive or suggest a false sense of history.

5. Driveways and Parking Lots

DESIGN PRINCIPLE: Significant driveway materials such as brick, concrete and asphalt should be preserved and maintained. New driveway or parking lot surfaces should be of a material appropriate to the site and the historic district. Paving and parking should not be visually dominant. Parking areas should not be sited in front yards but at side or rear locations, as appropriate.

Driveways and Parking Lots:

- A. should be maintained.
- B. that are new, should be located at the side or rear of the building and not be visually dominant.
- C. should be of concrete, asphalt, pavers or grassy pavers.
- D. should have their parking areas located in rear yards and be screened with hedges, shrubs or fences as appropriate. Driveways should include concrete tracks where characteristic of the property and historic districts.
- E. should not be sited in front yards.
- F. requiring new curb cuts for access should be kept to a minimum.
- G. On vacant lots between buildings should align edge screening with front elevations/facades of adjacent buildings and on corner lots should have edge screening on both the primary and secondary street.
- H. Driveways and parking lots shall have appropriate retention elements to retain gravel and retard expansion.

Findings

The proposal to construct a mudroom and sunroom are within Guidelines II.A.4.A.B. which state, "located at the rear of the building," "secondary (smaller and simpler) to the original building in scale, design, and placement." an "compatible design in keeping with the original building's design." However, staff finds that the mudroom and sun room construction should be modified

Findings

slightly and the base should change from brick to be with Guideline II.A.4.I which states, “addition materials should be compatible with the historic fabric of the house. The use of wood is most appropriate; however cementitious board may be considered for additions.” Porch material should not mimic history or create too heavy an appearance.

Recommendations

The staff recommends approval of the sun room with the following conditions:

1. Change the brick base to another material.
2. After final review by other LFCUG divisions all changes shall be returned to Staff for review and approval prior to the start of any work.
3. If any changes are made that alter the information submitted, resubmit the changes to staff for review and approval prior to the start of the work.

Deadline for BOAR Action

March 5, 2021